

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM
LISTING SERVICE

LISTING No. 8534-0149:104 Page 1 of 1

CATEGORY: Nonmetallic Ducts

LISTEE: Flexible Technologies, PO Box 888, Abbeville, SC 29620
Contact: *D. Simpson (864) 459-5441

DESIGN: Model FLEXVENT "KP" non metallic, flexible air duct. The duct consists of a wire helix and polyester film liner covered with one layer of fiberglass and facing material. Sizes are ranging from 4" to 20". Refer to listee's data sheet for detailed product description and operational considerations.

RATING: Maximum Velocity: 5000 fpm

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, duct type, type of joint system, maximum velocity/pressures, UL label.

APPROVAL: Listed as a Class I nonmetallic duct.

*Rev. 06-13-2000



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **MARCH 20, 2001**

*Listing Expires **June 30, 2002***

Authorized By: **BEN HO**, Supervising Deputy
Program Manager